

**BOONSBORO/KEEDYSVILLE REGIONAL WATER SYSTEM**  
**2012 ANNUAL DRINKING WATER QUALITY REPORT**  
**PWSID #0210002**

We are very pleased to present to you the Boonsboro/Keedysville Regional Water System's Annual Drinking Water Quality Report for the 2012 calendar year. Our goal is to consistently provide you with a safe and dependable supply of drinking water by continuing to improve the water treatment process and taking the extra steps to protect our valuable water resources. We are committed to ensuring the safe quality of the water that reaches your tap which is reflected in the monitoring results included in this report.

**Your drinking water comes from the Tomstown Dolomite, a ground water source made of carbonate rock, which forms an aquifer feeding a combination of wells and springs which is filtered, chlorinated and processed *with fluoride* through the Boonsboro and Keedysville Water Treatment Plants. The Boonsboro/Keedysville Water System staff diligently monitor for constituents in your drinking water insuring safety according to Federal and State laws.**

**Your water is tested because all sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk.**

**Is my water safe?** Of the some 122 regulated and unregulated contaminants identified a maximum Contaminant Level (MCL) by the Environmental Protection Agency (EPA), none were at violations levels ensuring that your tap water is safe to drink.

**Do I need to take special precautions?** Food and Drug Administration (FDA) regulations set limits for contaminants in bottled water that must provide the same protection for public health. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the EPA *Safe Drinking Water Hotline* 1-800-426-4791.

**If present, elevated levels of lead can also cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA *Safe Drinking Water Hotline* at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>."**

**A Source Water Assessment for the Boonsboro/Keedysville Regional Water System was prepared by the Maryland Department of the Environment's Water Supply Program and is available for public review by contacting the Town of Boonsboro at 301-432-5141 or the Town of Keedysville at 301-432-5795.**

**To learn more about your town's water system, please attend the monthly meeting of the Boonsboro Municipal Utilities Commission or the Keedysville Water Board. For information regarding meeting dates, times and locations, please contact your local town hall or visit [www.town.boonsboro.md.us](http://www.town.boonsboro.md.us) and [www.keedysvillemd.com](http://www.keedysvillemd.com)**

*"In accordance with Federal law and U.S. Department of Agriculture policy, this institution is prohibited from discrimination on the basis of race, color, national origin, sex, age, familial status, religion, or disability. To file a complaint of discrimination you may file in person with, or write to USDA, Director, Office of Civil Rights, 1400 Independence Avenue, SW., Washington, DC 20250-9410 or call (800)795-3272 (voice) or (202)720-6382 (TDD)".*

## 2012 Boonsboro/Keedysville Water Quality Test Results

The table below represents drinking water contaminants detected for the 2012 calendar year. Some of the data represented in this report is more than one year old. This is because the state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminant	Source	Sample Date	Unit of Measure	MCLG	MCL/ TT	Your Water	Violation	Typical Source of Contamination
<b>Volatile Organic Chemicals (VOC's)</b>								
HAA5 Haloacetic Acids	D	2012	ppb	N/A	60	1.16	N	By-product of drinking water chlorination
TTHM Total Trihalomethanes	D	2012	ppb	N/A	80	4.00	N	
<b>Radioactive Contaminants</b>								
Alpha emitters	2	2012	pCi/L	0	15	4.3	N	Erosion of natural deposits
Alpha emitters	3	2012	pCi/L	0	15	2.9	N	
Radium-226	2	2012	pCi/L	0	5	.4	N	
Beta/photon emitters	2	2012	pCi/L	0	50	4.2	N	Decay of natural and man-made deposits
<b>Inorganic Contaminants</b>								
Fluoride	1	2012	ppm	4	4	.08	N	Erosion of natural deposits; water additives promoting strong teeth; discharge from fertilizer and aluminum factories
Fluoride	2	2012	ppm	4	4	.74	N	
Fluoride	3	2012	ppm	4	4	.47	N	
Nitrate	1	2012	ppm	10	10	3.4	N	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits
Nitrate	2	2012	ppm	10	10	4.6	N	
Nitrate	3	2012	ppm	10	10	4.3	N	
Copper	consumers tap	2011	ppm	1.3	1.3	.33	N	Corrosion of household plumbing systems, Erosion of natural deposits
Lead		2011	ppm	0	0.015	0	N	
<b>Synthetic Organic Contaminants including Pesticides and Herbicides</b>								
Dinoseb	2	2010	ppb	7	7	.1	N	Runoff from herbicides used on soybeans and vegetables
<b>Unregulated Contaminants- monitoring of unregulated contaminants helps EPA to determine where certain contaminants occur and whether the Agency should consider regulating those contaminants in the future.</b>								
Sodium	1	2012	ppm	N/A	N/A	16.3	N	Erosion of natural deposits
Sodium	2	2012	ppm	N/A	N/A	26.2	N	
Sodium	3	2012	ppm	N/A	N/A	15.5	N	
Dibromochloromethane	1	2012	ppm	N/A	N/A	1.4	N	Byproducts of Chlorine disinfection
Bromodichloromethane	1	2012	ppm	N/A	N/A	2.1	N	
Chloroform	1	2012	ppm	N/A	N/A	3.7	N	
Chloromethane	1	2012	ppb	N/A	N/A	4.5	N	Airborne, burning/rotting wood, grass, charcoal
Chloromethane	2	2012	ppb	N/A	N/A	.6	N	
<b>Drinking Water Definitions and (Unit) Descriptions</b>								
<b>MCLG</b>	Maximum Contaminant Level Goal; the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.							
<b>MCL</b>	Maximum Contaminant Level; the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.							
<b>NA</b>	Not Applicable							
<b>NTU</b>	Nephelometric Turbidity Unit. A measure of the clarity of water.							
<b>ppb (ug/L)</b>	Parts Per Billion (micrograms per liter). One part per billion corresponds to one minute in 2,000 years.							
<b>ppm (mg/L)</b>	Parts Per Million (milligrams per liter). One part per million corresponds to one minute in two years.							
<b>pCi/L</b>	Picocuries per liter--measure of radioactivity in water.							
<b>Source</b>	Monitoring results are for three water sources and the distribution system as a whole (noted as 1, 2, 3 & D)							
<b>TT</b>	Treatment Technique. Required process to reduce the level of a contaminant in drinking water.							

The Town's of Boonsboro and Keedysville take great pride in providing the best quality of water possible to every tap. We ask all of our customers to invest in the welfare of our children's future by helping us to protect and safeguard our water sources.

For more information or questions regarding this report, please contact Boonsboro Town Manager Debra Smith at 301-432--5141 or [town.manager@myactv.net](mailto:town.manager@myactv.net) or visit the EPA website at [www.epa.gov/drink/index.cfm](http://www.epa.gov/drink/index.cfm)